



SANITARY CERTIFICATE

Ref. L. Dis. No. ⁴⁷⁸⁵ /A4/2024

O/o. District Health Officer,
Health Unit District,
Nagercoil.

Dt:

THE TAMILNADU EDUCATIONAL RULES CHAPTER-III (Rule 24 & Appendix-3)

I hereby declare that I have caused to be inspect the building and premises of
ST. Joseph International School, Kumarpuram Road
Asalvaimozhi
Thovalai Taluk, Kanyakumari District on 13.6.2024 and certify that the accommodation
provided for each and the several classes is sufficient for the maximum number of pupils taught therein and is
properly ventilated and lighted. That the building is maintained with substantial repairs and is neat and clean that
the latrine arrangements are adequate and satisfactory, that the supply of drinking water is wholesome and that in
all other necessary aspects the sanitation is satisfactory.

This certificate valid upto 31.5.2025.

Certificate is issued with the following conditions:

1. Establishing hand wash facilities at the entrance.
2. Toilets and Urinals must be kept hygienically clean and adequate water supply should be provided.
3. Environment and campus should be kept clean and neat and should be free from Dengue Aedes Larva.
4. Provide safe and protected drinking water.
5. First Aid box should be maintained with drug properly.
6. Tobacco prohibition board should be displayed as per COTPA 2003.

[Signature]
13/6/24

**BLOCK HEALTH SUPERVISOR
GOVT. PRIMARY HEALTH CENTRE
CHENBAGARAMANPUTHUR**

Countersigned on the basis of the BHS inspection finding

[Signature]
District Health Officer,
Health Unit District,
Nagercoil.





TEST WATER BEFORE TASTE
TAMIL NADU WATER SUPPLY & DRAINAGE BOARD

District Level Water Testing Laboratory,
TWAD Board, 46/50 Vellalar Colony, Ramavarnapuram, Nagercoil 629001.

TEST REPORT

Ph.04652-238315

From
Er.B.Hari Govind,B.E
Assistant Executive Engineer,
TWAD BOARD,
Maintenance Sub-Division,
Nagercoil-1.

To
St.Joseph International School,
Aralvaimozhi,
Kanyakumari District.

Lr.No.F.Drinking/ Lab No.41453-41454 /AEE(i.c)/Lab /NGI/20-21/Dated 12.10.2020.

Sir,

Sub : Examination of water sample - Report furnished - Reg.

Ref : 1) Your Lr.No.Nil/ Dt. 06.10.2020

2) Your D.D No. 088515/Dt.05.10.2020 for Rs.1652/-

3) Our Invoice No.8727/Dt. 06.10.2020 for Rs.1652/-

The result of analysis for the water sample sent under reference is furnished below.

Scheme : Drinking purpose

Source : Bore Well.

Location: Aralvaimozhi.

Date of Collection : 06.10.2020

Date of Receipt : 06.10.2020

BIS 10500 : 2012	Acceptable limit	Permissible limit in the absence of alternate source	Result
I. PHYSICAL EXAMINATION.			41453
1. Appearance	-	-	Clear
2. Colour	Agreeable	Agreeable	Colourless
3. Odour	-	-	None
4. Turbidity NT Units	1	5	0
5. Total dissolved Solids mg/L	500	2000	131
6. Electrical Conductivity Micro mho/cm	-	-	198
II. CHEMICAL EXAMINATION:			
7. pH	6.5-8.5	6.5-8.5	6.89
8. Ph. Alkalinity as CaCo ₃ mg/L	-	-	0
9. Total Alkalinity. as CaCo ₃ mg/L	200	600	48
10. Total Hardness as CaCo ₃ mg/L	200	600	24
11. Calcium as Ca mg/L	75	200	5
12. Magnesium as Mg mg/L	30	100	3
13. Sodium as Na mg/L	-	-	24
14. Potassium as K mg/L	-	-	12
15. Iron as Fe mg/L	0.3	1.0	0.24
16. Manganese mg/L	0.1	0.3	0.00
17. Free Ammonia as NH ₃ mg/L	0.5	0.5	0.12
18. Nitrite as NO ₂ mg/L	-	-	0.00
19. Nitrate as NO ₃ mg/L	45	45	1
20. Chloride as Cl mg/L	250	1000	27
21. Fluoride as F mg/L	1.0	1.5	0.2
22. Sulphate as SO ₄ mg/L	200	400	6
23. Phosphate as PO ₄ mg/L	-	-	0.05
24. Tidy's Test 4 hrs.as O ₂ mg/L	-	-	0.28
BACTERIOLOGICAL EXAMINATION			41454
Fecal coliform per 100 ml.	0	0	0

Report:Lab No.-41453: The water is chemically potable.

Report:Lab No.-41454: The Water is Bacteriologically Safe.

for

Assistant Executive Engineer, TWAD Board
Maintenance Sub-Division, Nagercoil

12/10/2020